

BUILDING LEAKAGE TEST

Date of Test: 04.06.2009
Test File: Untitled

Technician:

Customer: Jens Skårup

Building Address:

Phone:
Fax:

Airflow at 50 Pascals: 228 lps (+/- 0.2 %)
(50 Pa = 0.2 w.c.)

1.27 lps/m² Floor Area


Leakage Areas: 338.4 cm² (+/- 1.0 %) Canadian EqLA @ 10 Pa
184.9 cm² (+/- 1.6 %) LBL ELA @ 4 Pa

Minneapolis Leakage Ratio:

Building Leakage Curve: Flow Coefficient (C) = 20.2 (+/- 2.5 %)
Exponent (n) = 0.620 (+/- 0.006)
Correlation Coefficient = 0.99967

Test Standard: EN 13829 Test Mode: Depressurization
Type of Test Method: B Regulation complied with:
Equipment: Model 4 (230V) Minneapolis Blower Door

Inside Temperature: 14 °C Volume:
Outside Temperature: 10 °C Surface Area:
Barometric Pressure: 101325 Pa Floor Area: 180 m²
Wind Class: 3 Gentle Breeze Uncertainty of
Building Wind Exposure: Highly Protected Building Building Dimensions: 12 %
Type of Heating: Year of Construction:
Type of Air Conditioning:
Type of Ventilation: None



BUILDING LEAKAGE TEST Page 2

Date of Test: 04.06.2009 Test File: Untitled

Comments

Data Points:

Nominal Building Pressure (Pa)	Fan Pressure (Pa)	Nominal Flow (lps)	Temperature Adjusted Flow (lps)	% Error	Fan Configuration
-0.3	n/a				
-60.1	131.4	258	255	-0.1	Ring B
-55.3	118.0	244	242	-0.2	Ring B
-51.3	107.3	233	231	-0.2	Ring B
-45.5	93.8	218	216	0.6	Ring B
-40.5	80.0	202	199	-0.1	Ring B
-34.5	66.6	184	182	0.8	Ring B
-30.2	55.1	167	166	-0.2	Ring B
-25.3	43.4	149	147	-0.9	Ring B
-0.4	n/a				
Test 1 Baseline (Pa):		p01- = -0.3	p01+ = 0.0	p02- = -0.4	p02+ = 0.0